

Neschen Coating GmbH Hans-Neschen-Straβe 31675 Bückeburg Germany

Your message - reference	our reference	Gent
-	JW/4041	2023-11-17

Certification report 23/4041

1. Description of the product:

Product family	Decorative wallcovering made of non-woven fabric and PVC-free surface
Total mass	170 - 215 g/m²
Thickness	0.22 mm

2. Test results:

EN ISO 11925-2 (exposure=30s)	EN 13823

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

addressee	our reference	Gent	page
Neschen Coating GmbH	JW/4041	2023-11-17	2

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows according EN 13501-1:2018:

C – s1, d0	
if glued to substrates having a Euroclass A2-s1,d0 or A1 which density is superior to 525 kg/m ³	

Related commercial names to this product group	NESCHEN wallpaper LITE smooth NESCHEN wallpaper LITE sand NESCHEN wallpaper L-UV sand
The obtained classification is based on the next test reports	CREPIM: DO-23-5294\A-R1 dd 09-11-2023
Validity of the certificate	08-11-2028

Jo Wynendaele, PhD

Consultant Floor and Wall Coverings

Ju grendee