

Neschen Coating GmbH Hans-Neschen-Straβe 31675 Bückeburg Germany

Your message - reference	our reference	Gent
' - '	JW/219	2024-01-19

Certification report 24/219

## 1. Description of the product:

Product family	Self-adhesive wallcovering composed of a paper backing, PVC-free finish
Total mass Thickness	184 g/m <sup>2</sup> 0.19 mm

## 2. Test results:

EN ISO 11925-2 (exposure=30s)	EN 13823
-------------------------------	----------

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

## **CENTEXBEL • textile competence centre • www.centexbel.be**

addressee	our reference	Gent	page
Neschen Coating GmbH	JW/219	2024-01-19	2

## **Conclusion:** 3.

Referring to the means of control and the test results, the before mentioned product group can be classified as follows according EN 13501-1:2018:

$$B - s1, d0$$

 $B-s1,\ d0$  if mounted to substrates having a Euroclass A2-s1,d0 or A1 which density is superior to 525kg/m³

Related commercial names to this product group	UVPrint PP easy dot transparent
The obtained classification is based on the next test reports	CREPIM: DO-24-5542\A-R1 dd 18-01-2024
Validity of the certificate	17-01-2029

Jo Wynendaele, PhD

Consultant Floor and Wall Coverings